

OFFICE OF THE STATE FIRE MARSHAL

REQUIREMENTS FOR INSTALLATIONS OF
ABOVEGROUND/UNDERGROUND STORAGE FUEL TANKS

THE FOLLOWING ITEMS ARE **REQUIRED** TO BE SUBMITTED TO THE OFFICE OF THE STATE FIRE MARSHAL FOR REVIEW AND APPROVAL OF UNDERGROUND OR ABOVEGROUND FUEL STORAGE TANK(S) AND RELATED SYSTEMS:

1. An accurate site plan that includes property lines, all buildings located on the property and existing fire protection equipment. The site plan should be to scale or have measurements on it.
2. An installation drawing showing how the tanks, piping, valves, pumps, vents and electrical systems will look when installed. If possible, include necessary dimensions.

Include equipment specifications. These specifications should include any manufacture's installation instructions or engineering specifications.

-
- Submit two (2) identical sets of documents for review and include any item not mentioned above if deemed appropriate for this installation.
 - If you have any questions regarding either aboveground or underground fuel storage tank installations or specific requirements please contact this office at (602) 364 -1003.

Ron Gonos
Deputy State Fire Marshal II

Revised 5/07/09