



OFFICE OF THE STATE FIRE MARSHAL



JANICE K. BREWER
GOVERNOR

GENE PALMA
DIRECTOR

ROBERT BARGER
FIRE MARSHAL

1110 WEST WASHINGTON, SUITE 100
PHOENIX, ARIZONA 85007
(602) 364-1003
(602) 364-1084 FAX

Abandoned fuel tanks in place

- **A certified licensed contractor shall be present for the closure of the underground tank.**
- **Any tank(s) with flammable or combustible product inside the tank(s) shall be tripled rinsed and vacuumed to remove all products out of the tank**
- **If the tank is empty and no readings are measured by using a combustible gas meter, it will not be necessary to triple rinse the tank(s).**
- **Reason for leaving and abandoning fuel tank in place due to tank or portion of the tank under a permanent structure; or if tank is removed, it will cause an undermine condition under a structure; or if the tank is severely decomposed where is would be unsafe to lift and remove the tank; or the area is inaccessible to heavy equipment for tank removal.**
- **When filling the tank with concrete, foam or other approved type material, be certain the tank is completely filled without having any air gaps between the top of the tank and product used for filling.**
- **If at all possible, all piping and tank vents are to be capped or sealed.**
- **Inspector to fill ou the ADEQ on site Underground Storage Tank Closure report form.**

This form is used only as a guide. Final approval is contingent of favorable field inspection.