



OFFICE OF THE STATE FIRE MARSHAL



JANICE K. BREWER
GOVERNOR

GENE PALMA
DIRECTOR

ROBERT BARGER
FIRE MARSHAL

1110 WEST WASHINGTON, SUITE 100
PHOENIX, ARIZONA 85007
(602) 364-1003
(602) 364-1084 FAX

THE FOLLOWING ITEMS ARE REQUIRED TO BE SUBMITTED TO THIS OFFICE FOR REVIEW AND APPROVAL OF UNDERGROUND OR ABOVEGROUND FUEL STORAGE TANK(S) AND RELATED SYSTEMS

- 1. An accurate site plan, including property lines, buildings located on the same property, and existing fire protection equipment. The site plan should be to scale or have measurements on it.**
- 2. An installation drawing showing how the tanks, piping, valves, pumps, vents, and electrical systems will look when installed. If possible include all necessary dimensions.**
- 3. Include equipment specifications. These specifications should have any manufactures installation instructions, or engineering specifications.**
- 4. Submit two (2) identical sets of documents for review.**
- 5. Include any item not mentioned above if deemed appropriate for this installation.**

If there are any questions regarding Aboveground or Belowground Fuel Storage Tank Installations or specific requirements, please contact this office.